

Certificate of Assessment

No. 0084

"Copyright CSIRO 2010 ©"
Copying or alteration of this report
without written authorisation from CSIRO is forbidden.

We have examined the information submitted to us and appraised the suitability of the alternative items of hardware, in terms of Australian/New Zealand Standard 1905, Part 1-1997, for use with specific fire-rated doorsets, on behalf of

E Plus Building Products Pty Ltd
Level 26/44 Market Street,
SYDNEY NSW

CSIRO Materials Science and Engineering's report FSP 0415 describes a fire test conducted to evaluate the alternative items of hardware and report FCO-2433 described the evaluation of a modification to the Rivers lockset

PRODUCT NAME

& DESCRIPTION: LOCKSET: Rivers 2 and 4 point security locking system

CONCLUSION:

The fitting of the alternative items of hardware, to the previously tested doorsets as reported in Sponsored Investigation NI 2490, is permissible within the terms of clause 4.1 of Australian Standard 1905, Part 1-1997. The doorsets listed in the table below would qualify for the fire-resistance level shown, if fitted with the alternative items of hardware.

ITEM OF HARDWARE	DOORSET REPORT	FIRE RESISTANCE LEVEL (FRL)
<u>LOCKSET</u> : Rivers 2 and 4 point (including modified door frame detail)	NI 2490 (Including FCO-2433 modifications)	-/240/30

Issued on the 30th day of July 2010 without alterations or additions.

This Certificate will expire on 31 July 2015.



Garry E Collins
Manager, Fire Testing and Assessments

THIS CERTIFICATE SUPERSEDES CERTIFICATE No. 227 ISSUED ON 31 DECEMBER 2006



CSIRO Materials Science and Engineering
14 Julius Avenue, Riverside Corporate Park, North Ryde NSW 2113 AUSTRALIA
Telephone: 61 2 9490 5444 Facsimile: 61 2 9490 5555