



14 Julius Avenue, North Ryde NSW 2113
PO Box 52, North Ryde NSW 1670, Australia
T (02) 9490 5444 • ABN 41 687 119 230

Certificate of Assessment

No. 84

“Copyright CSIRO 2015 ©”
Copying or alteration of this report
without written authorization from CSIRO is forbidden.

We have examined the information submitted to us and appraised the suitability of the alternative items of hardware, in terms of Australian/New Zealand Standard 1905, Part 1-1997, for use with specific fire-rated doorsets, on behalf of

E Plus Building Products Pty Ltd
Unit 1, 6-8 Huntley Street
ALEXANDRIA NSW

CSIRO Infrastructure Technologies Report FSP 0415 describes a test conducted to evaluate the alternative items of hardware and Letter of Assessment report FCO-2433 described the evaluation of a modification to the Rivers lockset.

PRODUCT NAME

& DESCRIPTION: LOCKSET: Rivers 2 and 4 point security locking system

CONCLUSION:

The fitting of the alternative item of hardware, to the previously tested doorsets as reported in Sponsored Investigation reports numbered NI 2490 and Letter-Of-Assessment numbered FCO-2433, is permissible within the terms of clause 4.1 of Australian Standard 1905, Part 1-1997. The doorsets listed in the table below would qualify for the fire-resistance level shown, if fitted with the alternative items of hardware.

ITEM OF HARDWARE	DOORSET REPORT	FIRE RESISTANCE LEVEL (FRL) IN ACCORDANCE WITH AS 1530.4 -1997
<u>LOCKSET</u> : Rivers 2 and 4 point (including modified door frame detail)	NI 2490 and FCO-2433	-/240/30

Testing Officer: Chris Wojcik

Date of Test: 3 November 1995

Issued on the 23rd day of October 2015 without alterations or additions. This Certificate supersedes that dated 30th July 2010. This Certificate will expire on 31 October 2020.

Brett Roddy
Manager, Fire Testing and Assessments